

ISSUED 6 Jan 97



**LEGEND**

Existing Sewer & Access Chamber (A.C.)

Inspection Opening (I.O.)

Unless Otherwise Shown :-  
 . All easements to be 3m. wide  
 . Sewer to be located centrally in road carriageway and easement.

NOTE:  
 For locations of connections  
 (Ref. SCM Section K)

Minimum 1.2 clearance between sewer and 'back of block' SWD.

DB 94-0167 Plot mh-loc

Chg	Amendment - UPDATED 12-6-96
Drn	
Ckd	
Unit Ldr.	

Des	JIS
Drn	C.S.
Exm	
Unit Ldr.	

R.M.Jones  
 Executive Manager 14 / 6 / 96  
 ENGINEERING GROUP

**SOUTH AUSTRALIAN WATER CORPORATION**

**SA WATER**

**SEWER CONSTRUCTION MANUAL PAGE L2  
 ACCESS CHAMBER AND INSPECTION OPENING  
 LOCATIONS IN ROADWAYS  
 AND EASEMENTS**

Not to Scale

© This drawing is the property of the South Australian Water Corporation and shall not be copied without permission.