



NOTE:
1. Embedment and Trench Fill to be similar to that for a DN 150 UPVC sewer, as detailed in SCM Section 'G'.



PIPE MATERIALS
Details on this drawing are applicable to connections off UPVC sewers using:-
* approved UPVC plain wall pipes with solvent cement joints, and
* approved UPVC ribbed pipes fitted with dual rubber rings at each joint.

Chg	A	Amendment - 13-6-96	Des	J.I.S.	Amendment Authorisation
Drn	C.S.	Title Block amended	Drn	C.S.	R.M.Jones
Ckd			Exm		Executive Manager 14 / 6 / 96
Unit Ldr.			Unit Ldr.		ENGINEERING GROUP

SOUTH AUSTRALIAN WATER CORPORATION

SA WATER

SEWER CONSTRUCTION MANUAL PAGE K5
DN 100 & 150 UPVC CONNECTIONS
WITH RISER OFF UPVC SEWER

Not to Scale

© This drawing is the property of the South Australian Water Corporation and shall not be copied without permission.