

If you need help
with this audit,
or have concerns
with your supply,
please call us on
1300 650 950.



These images show the correct signage that must accompany recycled water supply taps.



Recycled Water

Your 30 minute safety audit

Interpreter service

We offer our customers a 24-hour interpreting service. Please call 13 14 50 and ask the operator for the language you require.

+Υπηρεσία Διερμηνείας τηλεφωνήστε στο 13 14 50

Servizio interpreti: per favore chiama 13 14 50

दुभाषिया सेवा: कृपया 13 14 50 पर फ़ोन करें

Cần Dịch Vụ Thông Ngôn, xin gọi cho số 13 14 50

传译服务：请拨打电话

sawater.com.au



Government of
South Australia

0018BI803



Recycled Water Audit

Step		Pass	Fail
1	At your water meter, leave your recycled water supply (the purple water meter) on and turn off your drinking water supply.		
2	Turn on all inside taps (both hot and cold) one by one. The test is successful if your supply runs dry and there is no water flowing through your taps. Turn each tap off.	<input type="checkbox"/>	<input type="checkbox"/>
3	Turn on taps to all appliances (dishwasher and washing machine). The test is successful if your supply runs dry.	<input type="checkbox"/>	<input type="checkbox"/>
4	Flush all toilets. Those connected to recycled water will refill using your recycled water supply and must have a purple tap with signage marked 'water not suitable for drinking'.	<input type="checkbox"/>	<input type="checkbox"/>
5	Turn on your outside taps, one by one. Those connected to the drinking water supply will run dry. The taps that do not run dry must be purple and have signage marked 'water not suitable for drinking'.	<input type="checkbox"/>	<input type="checkbox"/>
6	Turn on your drinking water meter. Turn off your purple recycled water meter.		
7	Slowly turn on the drinking water tap furthest from your meter. This will release air from the drinking water supply, then turn the tap off.		
8	Turn on your outside taps, one by one. Those connected to the recycled water supply will run dry. Turn each tap off. These taps require signage marked 'water not suitable for drinking'.	<input type="checkbox"/>	<input type="checkbox"/>
9	Flush all toilets. Those connected to recycled water will not refill and must have a purple tap and signage marked 'water not suitable for drinking'.	<input type="checkbox"/>	<input type="checkbox"/>
10	Turn on your recycled water meter. Slowly turn on the recycled tap furthest from the meter to release the air, your toilet cisterns will also refill. Turn the tap off.		

If you have not recorded a pass for all of these tests please call us to report it on 1300 650 950.

If you have passed each step, please record the date on the purple recycled water audit sticker inside your electricity meter box and retain this audit for future reference.

Your property has a recycled water supply for toilet flushing and garden irrigation.

To ensure your health and safety, an audit on properties with this water supply must be conducted every five years.

Using this 10 step process, you can audit your recycled water supply.

These audits are conducted to ensure:

- your recycled water supply and your drinking water supply are not cross connected.
- recycled water is supplied only to your toilet and garden taps/irrigation.

The audit will help you understand the water supply systems on your property and check the integrity of your drinking water supply.

