

Clause	Description		Requirement	Supporting Document
All		The products as listed in SA Water's SCM Authorised Items List continue to be the only products automatically authorised for use in SA Water's infrastructure.		
		Australia n	lucts listed in the Sewerage Code of nay be used in specific projects with the f SA Water.	
Table 10.1	VC Pipe System	No Vitrified Clay pipe is currently authorised by SA Water		
	PVC Pipe	The minimum allowable classes are as followsDN100SN6 (to AS/NZS 1260)DN150 to DN300SN4 (to AS/NZS 1260)		
	PVC Jointing system Reinforced Concrete pipe	SA Water uses only solvent welding for this material Reinforced concrete pipe is to be manufactured using calcareous aggregate. SA Water authorisation is to be obtained prior to use of reinforced concrete pipe.		
	GRP pipe	prior to the use of GRP pipe.		
	PE Plain Wall Pipe	SA Water requires PE 80 as the PE pipe material. For directional boring Minimum Pressure rating is to be PN16.		
	PE Jointing system	Butt welding of PE pipe in field applications is not acceptable to SA Water without project specific authorisation		
	ABS Pipe System	SA Water authorisation is to be obtained prior to the use of ABS pipe.		
	DI Pipe system	DI is only to be used for rising mains. SA Water authorisation may be given for other special applications (eg creek crossings)		
Table 10.3	Pressure mains	Minimum Pressure Rating (PN) is to be 1.5 times the maximum design pressure for the main.		
WSAA Website	http://www.wsaa.asn.au/frameset2.html		This is a very handy introduction to the latest product and material information. Listing on the WSAA website does not automatically guarantee product authorisation by SA Water and product selection is to be based on the SCM Authorised Items List	

	ADDITIONAL REQU
Description	SA
Maintenance Holes	Only Authorised Concrete MH is obtained.
Step Irons and ladders	Step Irons and ladders are not
Covers and Frames	All covers and frames are to be Non-road use DI/CI Class In-road use DI/CI Class Covers and frames to be as spe
Valves	All stop valves to be CLOCK

		To be used with WSA 02		
Issue 03	1 December 2009	Part 2 Page 1 of 1		
Z:\Users\Networks Engineering\Standards Docs\sewer manual\Manual Revision Jan 11				

SEWERAGE CODE OF AUSTRALIA AGENCY REQUIREMENTS

PART 2 - MATERIALS

UIREMENTS

SA Water Requirements IH systems are to be used unless project specific approval t to be installed in MH or other access structures be as follows:sΒ 5 D pecified in SCM Authorised Items List KWISE closing